

Definitions You Need To Know

Action Level - the concentration of a contaminant that, if exceeded, triggers treatment or other requirements a water system must follow.

Coliform Absent (ca) - Laboratory analysis indicates that the contaminant is not present.

Disinfection byproducts (DBPs) – are formed when disinfectants used in water treatment plants react with bromide and/or natural organic matter (i.e., decaying vegetation) present in the source water. Different disinfectants produce different types or amounts of disinfection byproducts. Disinfection byproducts for which regulations have been established include trihalomethanes (THM), haloacetic acids (HAA5), bromate, and chlorite.

Initial Distribution System Evaluation (IDSE) - a one-time study conducted by water systems to identify distribution system locations with high concentrations of trihalomethanes (THMs) and haloacetic acids (HAAs). Water systems will use results from the IDSE, in conjunction with their Stage 1 DBPR compliance monitoring data, to select compliance monitoring locations for the Stage 2 DBPR.

Locational Running Annual Average (LRAA) - yearly average of all the DPB results at each specific sampling site in the distribution system. The highest distribution site LRAA is reported in the Table of Detected Contaminants.

Maximum Contaminant Level (MCL) – The “Maximum Allowed” is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) – The “Goal” is the level of contaminant in drinking water below which there is no known or expected risk of health. MCLGs allow for margin of safety.

Maximum Residual Disinfection Level (MRDL) - the highest level of a disinfectant allowed in drinking water.

Millirems per year (mrem/yr) – Million fibers per liter is a measure of presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) – Nephelometric turbidity unit is a measure of the clarity of the water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Non-Detects (ND) – Laboratory analysis indicates that the constituent is not present above detection limits of lab equipment.

Not Reported (NR) - laboratory analysis, usually Secondary Contaminants, not reported by water system. EPA recommends secondary standards to water systems but does not require systems to comply.

Parts per billion (ppb) or Micrograms per liter – One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per million (ppm) or Milligrams per liter (mg/l) – One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per quadrillion (ppq) or Picograms per liter – One part per quadrillion corresponds to one minute in 2,000,000,000 years, or a single penny in \$10,000,000,000,000.

Parts per trillion (ppt) or Nanograms per liter – One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Picocuries per liter (pCi/l) – Picocuries per liter is a measure of the radioactivity in water.

RAA - Running annual average

Standard Units (S.U.) - pH of water measures the water’s balances of acids and bases and is affected by temperature and carbon dioxide gas. Water with less than 6.5 could be acidic, soft, and corrosive. A pH greater than 8.5 could indicate that the water is hard.

Treatment Technique (TT) – A required process intended to reduce the level of a contaminant in drinking water.

Variations & Exemptions (V&E) – State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

OUR DAILY WATER

Oxford Water Works & Sewer Board

2026 Annual Water Quality Report (Testing Performed January - December 2025)



OUR DAILY WATER

If you have any questions about this report or concerning your water, please contact our office. We want our valued customers to be informed about their water utility.

Oxford Water Works & Sewer Board
600 Barry Street, Post Office Box 3663
Oxford, Alabama 36203

Phone: 256-831-5618 Fax: 256-831-9063

Main Office Hours: 7:00 a.m. to 4:30 p.m. Monday—Friday
Water Board Meets 3rd Wednesday of each month at 12:00 p.m.

General Manager..... Wayne Livingston
Controller..... Patrick Prater
Engineer..... Meredith Holzer
Office Manager..... Amanda Moore

BANK DRAFT IS AVAILABLE - Saves you: Time – Postage – Checks



2026 Annual Water Quality Report

Testing Performed January through December 2025

Oxford Water Works & Sewer Board is pleased to present to you this year’s 2026 Annual Water Quality Report. This report is designed to inform you about the quality water and service we deliver to you on a daily basis, and our constant goal being to provide you with a safe and dependable supply of drinking water.

THE OXFORD WATER & SEWER SYSTEM INCLUDES:

Water Mains in Service.....318 miles
Sewer Mains in Service.....141 miles
Water Storage Tanks.....5
Water Treatment Plant.....1
Water Storage Capacity.....5.4 Million Gallons
Water Production Capacity.....12.0 Million Gallons Per Day
Booster Pumping Stations.....8
Public Fire Hydrants.....994
Sewer Treatment Capacity.....4.5 Million Gallons Per Day
Sewer Pumping Stations.....37
Metered Connections.....10,197

Oxford’s Water Supply is classified as Groundwater. Groundwater classification means the water is pumped from below the surface of the ground. Drinking water is supplied to customers of Oxford Water by five production wells that draw water from The Knox Group, Shady Dolomite Aquifer. Each well is approximately 300 feet deep and the water from each well meets all regulations without any treatment required; however, some chlorine is added to protect the water in tanks and distribution lines. The Oxford Quarry also provides water to the Oxford system and is filtered using membranes at the Leon Smith Water Treatment Plant. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activities.

The Oxford Water Works routinely monitors for constituents in your drinking water. For 2025, only 22 constituents were at detectable levels. All monitoring and testing were performed according to Federal and State Laws. This table shows the results of our monitoring for the period of January 1, 2025 to December 31, 2025 for Inorganics, Lead and Copper, Microbiological Contaminants, Nitrates, Synthetic Organic Contaminants, Volatile Organic Contaminants, Disinfection By-Products, PFAS Contaminants, and Cryptosporidium. All of these were performed in accordance with the regulatory monitoring schedule shown here.

Monitoring Schedule Per Constituent	Date
Inorganic Contaminants	2025
Lead/Copper	2025
Microbiological Contaminants	Monthly
Nitrates	2025
Radioactive Contaminants	2025
Synthetic Organic Contaminants (including pesticides & herbicides)	2025
Volatile Organic Contaminants	2025
Disinfection By-Products	2025
Unregulated Contaminants Monitoring Rule 4 (UCMR4) Contaminants	2020
PFAS Contaminants	2025
Cryptosporidium	2025

STANDARD LIST OF PRIMARY DRINKING WATER CONTAMINANTS							
Contaminant	MCL	Unit	Detections	Contaminant	MCL	Unit	Detections
Bacteriological Contaminants				1,1-Dichloroethylene	7	ppb	ND
Total Coliform Bacteria	<5%	present/absent	absent	cis-1,2-Dichloroethylene	70	ppb	ND
Fecal Coliform and E. coli	0	present/absent	absent	trans-1,2-Dichloroethylene	100	ppb	ND
Turbidity	TT	NTU	0.021	Dichloromethane	5	ppb	ND
Cryptosporidium	TT	Calc. organism/l	ND	1,2-Dichloropropane	5	ppb	ND
Radiological Contaminants				Di (2-ethylhexyl)adipate	400	ppb	ND
Betalactam emitters	4	mrem/yr	ND	Di (2-ethylhexyl)phthalate	6	ppb	ND
Alpha emitters	15	pCi/l	2.65	Dioxob	7	ppb	ND
Combined radium	5	pCi/l	ND	Dioxin [2,3,7,8-TCDD]	30	ppq	ND
Uranium	30	pCi/l	ND	Diquat	20	ppb	ND
Inorganic Chemicals				Endothal	100	ppb	ND
Antimony	6	ppb	ND	Erdrin	2	ppb	ND
Arsenic	10	ppb	ND	Epichlorohydrin	TT	TT	ND
Asbestos	7	MFL	ND	Ethylbenzene	700	ppb	ND
Barium	2	ppm	0.038	Ethylene dibromide	50	ppt	ND
Beryllium	4	ppb	ND	Glyphosate	700	ppb	ND
Cadmium	5	ppb	ND	Heptachlor	400	ppt	ND
Chromium	100	ppb	ND	Heptachlor epoxide	200	ppt	ND
Copper	AL+1.3	ppm	0.02 - 0.03	Hexachlorobenzene	1	ppb	ND
Cyanide	200	ppb	ND	Hexachlorocyclopentadiene	50	ppb	ND
Fluoride	4	ppm	ND - 0.28	Lindane	200	ppt	ND
Lead	AL+15	ppb	ND (ND - 0.012)	Methoxychlor	40	ppb	ND
Mercury	2	ppb	ND	Oxamyl [Vydate]	200	ppb	ND
Nitrate	10	ppm	ND-1.1	Polychlorinated biphenyls	0.5	ppb	ND
Nitrite	1	ppm	ND	Pentachlorophenol	1	ppb	ND
Selenium	0.05	ppm	ND	Picloram	500	ppb	ND
Thallium	0.002	ppm	ND	Simazine	4	ppb	ND
Organic Contaminants				Styrene	100	ppb	ND
2,4-D	70	ppb	ND - 0.15	Tetrachloroethylene	5	ppb	ND
Acrylamide	TT	TT	ND	Toluene	1	ppm	ND
Alachlor	2	ppb	ND	Toxaphene	3	ppb	ND
Benzene	5	ppb	ND	2,4,5-TP (Silvex)	50	ppb	ND
Benz(a)pyrene [PAHs]	200	ppt	ND	1,2,4-Trichlorobenzene	0.07	ppm	ND
Carbofuran	40	ppb	ND	1,1,1-Trichloroethane	200	ppb	ND
Carbon tetrachloride	5	ppb	ND	1,1,2-Trichloroethane	5	ppb	ND
Chlordane	2	ppb	ND	Trichloroethylene	5	ppb	ND - 4.1
Chlorobenzene	100	ppb	ND	Vinyl Chloride	2	ppb	ND
Dalapon	200	ppb	ND	Xylenes	10	ppm	ND
Dibromochloropropane	200	ppt	ND	Disinfectants & Disinfection Byproducts			
1,2-Dichlorobenzene	1000	ppb	ND	Chlorine	4	ppm	1.03 - 1.86
1,4-Dichlorobenzene (para)	75	ppb	ND	THM (Total trihalomethanes)	80	ppb	1.3 - 44.0
o-Dichlorobenzene	600	ppb	ND	HAA5 (Total haloacetic acids)	60	ppb	ND - 30.0
1,2-Dichloroethane	5	ppb	ND				

SECONDARY CONTAMINANTS					
Alkalinity, Total (as CaCO3)	Chloride	Iron	Foaming Agents (MBS)	Odor	Sulfate
Aluminum	Copper	Magnesium	Sodium	Color	Zinc
Calcium, as Ca	Corrosivity	Manganese	Specific Conductance	pH	
Carbon Dioxide	Hardness	Nickel	Total Dissolved Solids	Silver	
UNREGULATED CONTAMINANTS					
1,1 - Dichloropropene	Aldicarb	Paraquat	N-Butylbenzene	Methyl-tert-butyl ether	
1,1,1,2-Tetrachloroethane	Aldicarb Sulfone	Aldrin	Sec-Butylbenzene	Metalachlor	
1,1,2,2-Tetrachloroethane	Aldicarb Sulfoxide	Bromofom	Tert-Butylbenzene	Melribuzin	
1,1-Dichloroethane	Bromobenzene	Bromomethane	O-Chlorotoluene	Naphthalene	
1,2,3 - Trichlorobenzene	Bromochloromethane	Bulachlor	P-Chlorotoluene	1-Naphthol	
1,2,3 - Trichloropropane	Bromodichloromethane	Carbaryl	Isopropylbenzene	Popachlor	
1,2,4 - Trimethylbenzene	Bromoacetic Acid	Chloroethane	P-Isopropyltoluene	Tetrachloroethene	
1,3 - Dichloropropane	Chloromethane	Chloroform	M-Dichlorobenzene	Trichloroacetic Acid	
1,3 - Dichloropropane	Dibromochloromethane	Dicamba	Methylene Chloride	Trichloroethene	
1,3,5 - Trimethylbenzene	Dibromomethane	Dieldrin	3-Hydroxycarbofuran	Trichlorofluoromethane	

Oxford Water Works & Sewer Board is a member of American Water Works Association (AWWA), Alabama Rural Water Association (ARWA), the National Rural Water Association (NRWA), Alabama’s Water Environment Association (AWEA), and the Groundwater Foundation.



TABLE OF DETECTED DRINKING WATER CONTAMINANTS

Contaminants	Violation (Yes/No)	Level Detected	Unit of Measure	MCLG	MCL	Likely Source of Contamination
Chlorine	No	1.03- 1.86	ppm	MRDLG=4	MRDL=4	Water additive used to control microbes
Total Organic Carbon	No	0.5 - 1.40	ppm	N/A	TT	Soil runoff
Turbidity	No	0.021*	NTU	N/A	TT	Soil runoff
Barium	No	0.018 - 0.038	ppm	2	2	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Copper (customer tap)	No	0.095* Range 0.02 - 0.30	ppm	1.3	AL=1.3	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives
2,4-D	No	0.15	ppb	70	70	Runoff from herbicide used on row crops
Fluoride	No	ND - 0.28	ppm	4	4	Erosion; water additive for teeth; discharge from fertilizer and aluminum factories
Alpha Emitters	No	2.65	PCI/l	0	15	Erosion of natural deposits
Lead	No	0.000* Range ND - 0.012	Ppm	0	AL= 0.015	Corrosion of household plumbing systems; erosion of natural deposits
Nitrate (as Nitrogen)	No	ND - 1.1	ppm	10	10	Runoff from fertilizer use; leaching from septic tanks; sewage; erosion of natural deposits
Trichloroethylene	No	Av8 3-43 Range ND - 4.1	ppb	0	5	Discharge from metal degreasing sites and other industries
TTHM (Total Trihalomethanes)	No	Highest 18.7 Range 1.3 - 44.0	ppb	0	80	By-product of drinking water chlorination
HAA5 (Haloacetic Acids)	No	Highest 18.0 Range ND - 30.0	ppb	0	60	By-product of drinking water chlorination

Unregulated Contaminants

Chloroform	No	8.2	ppb	N/A	N/A	Naturally occurring in the environment or from runoff
Bromodichloromethane	No	4.1	ppb	N/A	N/A	Naturally occurring in the environment or from runoff
Chlorodibromomethane	No	1.1	ppb	60	N/A	Naturally occurring or from discharge or runoff

Secondary Contaminants

Chloride	No	ND - 5.2	ppm	N/A	250	Naturally occurring or from discharge or runoff
Hardness	No	106 - 163	ppm	N/A	N/A	Naturally occurring or from water additives
pH	No	7.5 - 8.0	S.U.	N/A	N/A	Naturally occurring or from water additives
Sulfate	No	ND - 5.4	ppm	N/A	250	Naturally occurring; erosion of natural deposits
Sodium	No	ND - 2.4	ppm	N/A	N/A	Naturally occurring in the environment
Total Dissolved Solids	No	102 - 149	ppm	N/A	500	Naturally occurring or from discharge or runoff

As you can see by the table, our system had NO drinking water quality violations. We are proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water **IS SAFE** at these levels. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect. Thank you for allowing us to continue providing your family with clean quality water this year. In order to maintain a safe and dependable water supply, we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for your understanding. Please call our office if you have any questions.

The Safe Drinking Water Act (SDWA) was signed into law on December 16, 1974. The purpose of the law is to assure that the nation's water supply systems serving the public meet the minimum national standards for the protection of public health. The SDWA covers all public water systems with piped water for human consumption with at least 15 service connections or a system that regularly serves at least 25 individuals. The SDWA directed the U.S. Environmental Protection Agency (EPA) to establish national drinking water standards. These standards limit the amount of certain contaminants provided by public water. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water. All drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 800-426-4791.

The most recent testing for lead and copper compliance within the distribution system was in 2025. This testing was done in accordance with applicable regulations. **No lead or copper samples exceeded the action level.** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Oxford Water Works and Sewer Board is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and other steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. Oxford Water has completed the lead line inventory. **There were NO lead service lines and NO galvanized-requiring replacement service lines found.** To access the interactive online map, please visit www.oxfordwater.com and select Service Line Inventory.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791). PFAS are a group of manmade chemicals that have been in use since the 1940s. Because of their widespread use, most people have been exposed to PFAS and there is evidence that exposure to PFAS may lead to adverse health effects. Below is a list and results of PFAS contaminants Oxford monitored during 2025. For more information, visit www.epa.gov/pfas.

Contaminant	Unit Msmt	Level Detected	Contaminant	Unit Msmt	Level Detected
11CI-PF3OUdS (11-chloroicosasfluoro-3-	ppb	ND	Perfluorododecanoic acid	ppb	ND
9CI-PF3ONS (9-chlorohexadecafluoro-3-	ppb	ND	Perfluoroheptanoic acid	ppb	ND
ADONA (4,8-dioxia-3H-perfluorononanoic acid)	ppb	ND	Perfluorohexanesulfonic acid	ppb	ND-0.003
HFPO-DA (Hexafluoropropylene oxide dimer acid)	ppb	ND	Perfluorononanoic acid	ppb	ND
NEFOSAA (N-ethylperfluorooctanesulfonamidoacetic acid)	ppb	ND	Perfluorooctanesulfonic acid	ppb	0.0041-0.0065
NMFOSAA (N-methylperfluorooctanesulfonamidoacetic acid)	ppb	ND	Perfluorooctanoic acid	ppb	0.0018-0.0024
Perfluorobutanesulfonic acid	ppb	ND-0.0019	Perfluorotetradecanoic acid	ppb	ND
Perfluorodecanoic acid	ppb	ND	Perfluorotridecanoic acid	ppb	ND
Perfluorohexanoic acid	ppb	ND-0.0027	Perfluoroundecanoic acid	Ppb	ND

Your source water is also monitored for pathogens, such as Cryptosporidium and Giardia. These pathogens can enter the water from animal or human waste. For people who may be immunocompromised, a guidance document developed jointly by Environmental Protection Agency and Center for Disease Control is available online at www.epa.gov/safewater/crypto.html. All raw source water test results were well within State and Federal standards. **Cryptosporidium and Giardia have not been detected in our finished drinking water.**

Cryptosporidium and Giardia (in Cysts/10L) - Raw Source Water	
Cryptosporidium	ND
Giardia	ND

The Fourth Unregulated Contaminant Monitoring Rule (UCMR4) requires some systems to monitor for unregulated contaminants. The table below shows the results of monitoring during our assigned monitoring period. For more information on UCMR contaminants, please refer to www.epa.gov/dwucmr.

Unregulated Contaminant Rule 4 (UCMR4) Contaminants					
Contaminant	Unit Msmt	Level Detected	Contaminant	Unit Msmt	Level Detected
Germanium	ppb	ND	tbutanol	ppb	ND
Manganese	ppb	ND-48.8	2-methoxyethanol	ppb	ND
Alpha-hexachlorocyclohexane	ppb	ND	2-propanol-1ol	ppb	ND
Chlorpyrifos	ppb	ND	Bisulfated hydroxyanisole	ppb	ND
Dimethipin	ppb	ND	O-toluidine	ppb	ND
Ethioprop	ppb	ND	Quinoline	ppb	ND
Oxyfluoren	ppb	ND	Total organic carbon (TOC)	ppb	1090-1120
Profenofos	ppb	ND	Bromide	ppb	ND
Tebuconazole	ppb	ND	HAA9	ppb	ND-2.10
Total permethrin (cis- & trans-)	ppb	ND	HAA6Br	ppb	ND
Tribufos	ppb	ND	HAA5	ppb	ND

* This turbidity reading, the highest for the entire year, lasted less than 15 minutes before returning to normal lower levels.

** Figure shown is 90th percentile from latest round of sampling, and number of sites exceeding the Action Level (AL) = 0.