

Alabama Department of Environmental Management Discharge Monitoring Report (DMR)

PERMITTEE NAME: Water Works & Sewer Board of the City of Oxford

PERMIT NUMBER: AL0058408

MAILING ADDRESS: Post Office Box 3663
Oxford, AL36203

MONITORING POINT: 0011

COUNTY:

FACILITY: Oxford Tull C Allen Wwtp
LOCATION:

Monitoring Period : 2021-02-01 To: 2021-02-28

NO DISCHARGE FROM SITE: ()

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
TURBIDITY	Sample Measurement	*****	*****		*****	2.26	3.36	43 NTU	0	5X Weekly	Grab
PARAM CODE: 00070 Stage Code: 1 Final Effluent	Permit Requirement	*****	*****		*****	REPORT Monthly Average	REPORT Maximum Daily				5X Weekly
OXYGEN, DISSOLVED (DO)	Sample Measurement	*****	*****		9.05	*****	*****	19 mg/l	0	3X Weekly test	Grab
PARAM CODE: 00300 Stage Code: 1 Final Effluent	Permit Requirement	*****	*****		6.0 Minimum Daily	*****	*****				3X Weekly test
PH	Sample Measurement	*****	*****		7.23	*****	7.51	12 S.U.	0	3X Weekly test	Grab
PARAM CODE: 00400 Stage Code: 1 Final Effluent	Permit Requirement	*****	*****		6.0 Minimum Daily	*****	9.0 Maximum Daily				3X Weekly test
SOLIDS, TOTAL SUSPENDED	Sample Measurement	4606	4799	26 lbs/day	*****	121	154	19 mg/l	0	3X Weekly test	24-Hr Composite
PARAM CODE: 00530 Stage Code: G Influent	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average			*****	REPORT Monthly Average		REPORT Weekly Average		
SOLIDS, TOTAL SUSPENDED	Sample Measurement	367	453	26 lbs/day	*****	8.8	9.8	19 mg/l	0	3X Weekly test	24-Hr Composite
PARAM CODE: 00530 Stage Code: 1 Final Effluent	Permit Requirement	1125 Monthly Average	1688 Weekly Average			*****	30.0 Monthly Average		45.0 Weekly Average		
NITROGEN, AMMONIA TOTAL (AS N)	Sample Measurement	10.33	37.3	26 lbs/day	*****	0.25	0.97	19 mg/l	0	3X Weekly test	24-Hr Composite
PARAM CODE: 00610 Stage Code: 1 Final Effluent	Permit Requirement	750 Monthly Average	1125 Weekly Average			*****	20.0 Monthly Average		30.0 Weekly Average		
NITROGEN, KJELDAHL TOTAL (AS N)	Sample Measurement	32	32	26 lbs/day	*****	1.10	1.10	19 mg/l	0	Monthly	24-Hr Composite
PARAM CODE: 00625 Stage Code: 1 Final Effluent	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average			*****	REPORT Monthly Average		REPORT Weekly Average		
Name/Title of Principal Executive Officer Or Authorized Agent	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. §1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months to 5 years.)					Signature of Principal Executive Officer Or Authorized Agent		Telephone No	Date (MM/DD/YY)		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Alabama Department of Environmental Management Discharge Monitoring Report (DMR)

PERMITTEE NAME: Water Works & Sewer Board of the City of Oxford

PERMIT NUMBER: AL0058408

MAILING ADDRESS: Post Office Box 3663
Oxford, AL36203

MONITORING POINT: 0011

COUNTY:

FACILITY: Oxford Tull C Allen Wwtp

Monitoring Period : 2021-02-01 To: 2021-02-28

NO DISCHARGE FROM SITE: ()

Parameter		Quantity or Loading		Units	Quality or Concentration		Units	No. Ex.	Frequency of Analysis	Sample Type	
NITRITE PLUS NITRATE TOTAL 1 DET. (AS N) PARAM CODE: 00630 Stage Code: 1 Final Effluent	Sample Measurement	65	65	26 lbs/day	*****	2.20	2.20	19 mg/l	0	Monthly	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		*****	REPORT Monthly Average	REPORT Weekly Average		Monthly	24-Hr Composite	
PHOSPHORUS, TOTAL (AS P) PARAM CODE: 00665 Stage Code: 1 Final Effluent	Sample Measurement	3	3	26 lbs/day	*****	0.11	0.11	19 mg/l	0	Monthly	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		*****	REPORT Monthly Average	REPORT Weekly Average		Monthly	24-Hr Composite	
SILVER TOTAL RECOVERABLE PARAM CODE: 01079 Stage Code: 1 Final Effluent	Sample Measurement	*****	*****		*****	*B	*B	28 ug/l	0	Monthly	Grab
	Permit Requirement	*****	*****		*****	REPORT Monthly Average	REPORT Maximum Daily		Monthly	Grab	
COLOR (ADMI UNITS) PARAM CODE: 01290 Stage Code: 1 Final Effluent	Sample Measurement	*****	*****		*****	*****	54	1E ADMI	0	5X Weekly	Grab
	Permit Requirement	*****	*****		*****	*****	80 Maximum Daily		5X Weekly	Grab	
FLOW, IN CONDUIT OR THRU TREATMENT PLANT PARAM CODE: 50050 Stage Code: 1 Final Effluent	Sample Measurement	4.98	8.73	03 MGD	*****	*****	*****		0	Daily	Continuous
	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily		*****	*****	*****		Daily	Continuous	
CHLORINE, TOTAL RESIDUAL PARAM CODE: 50060 Stage Code: 1 Final Effluent	Sample Measurement	*****	*****		*****	*9	*9	19 mg/l	0	3X Weekly test	Grab
	Permit Requirement	*****	*****		*****	0.066 Monthly Average	0.115 Maximum Daily		3X Weekly test	Grab	
E.COLI PARAM CODE: 51040 Stage Code: 1 Final Effluent	Sample Measurement	*****	*****		*****	6	33	13 col/100mL	0	5X Weekly	Grab
	Permit Requirement	*****	*****		*****	548 Monthly Average	2507 Maximum Daily		5X Weekly	Grab	
Name/Title of Principal Executive Officer Or Authorized Agent	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION. I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. §1319 (Penalties under these statutes may include fines up to \$10,000 and/or maximum imprisonment of between 6 months to 5 years.)					Signature of Principal Executive Officer Or Authorized Agent		Telephone No	Date (MM/DD/YY)		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Alabama Department of Environmental Management Discharge Monitoring Report (DMR)

PERMITTEE NAME: Water Works & Sewer Board of the City of Oxford
MAILING ADDRESS: Post Office Box 3663
 Oxford, AL36203
FACILITY: Oxford Tull C Allen Wwtp
LOCATION:

PERMIT NUMBER: AL0058408

MONITORING POINT: 0011

COUNTY:

Monitoring Period : 2021-02-01To: 2021-02-28

NO DISCHARGE FROM SITE: ()

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
CYANIDE, FREE AVAILABLE PARAM CODE: 51173 Stage Code: 1 Final Effluent	Sample Measurement	*****	*****		*****	*B	*B	28 ug/l	0	Monthly	Grab
	Permit Requirement	*****	*****		*****	31.4 Monthly Average	70.5 Maximum Daily				Monthly
PERACETIC ACID PARAM CODE: 51674 Stage Code: 1 Final Effluent	Sample Measurement	*****	*****		*****	*****	0.21	19 mg/l	0	5X Weekly	Grab
	Permit Requirement	*****	*****		*****	*****	1.0 Maximum Daily				5X Weekly
BOD, CARBONACEOUS 05 DAY, 20C PARAM CODE: 80082 Stage Code: G Influent	Sample Measurement	2748	3765	26 lbs/day	*****	71	75	19 mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		*****	REPORT Monthly Average	REPORT Weekly Average				3X Weekly test
BOD, CARBONACEOUS 05 DAY, 20C PARAM CODE: 80082 Stage Code: 1 Final Effluent	Sample Measurement	178	315	26 lbs/day	*****	4.3	6.3	19 mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	938 Monthly Average	1407 Weekly Average		*****	25.0 Monthly Average	37.5 Weekly Average				3X Weekly test
BOD, CARB-5 DAY, 20 DEG C, PERCENT REMVL PARAM CODE: 80091 Stage Code: K Percent Removal	Sample Measurement	*****	*****		94	*****	*****	23 %	0	Monthly	Calculated
	Permit Requirement	*****	*****		85.0 Monthly Average Minimum	*****	*****				Monthly
SOLIDS, SUSPENDED PERCENT REMOVAL PARAM CODE: 81011 Stage Code: K Percent Removal	Sample Measurement	*****	*****		91	*****	*****	23 %	0	Monthly	Calculated
	Permit Requirement	*****	*****		85.0 Monthly Average Minimum	*****	*****				Monthly
Name/Title of Principal Executive Officer Or Authorized Agent	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. §1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months to 5 years.)					Signature of Principal Executive Officer Or Authorized Agent		Telephone No	Date (MM/DD/YY)		

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)

Alabama Department of Environmental Management Discharge Monitoring Report (DMR)

PERMITTEE NAME: Water Works & Sewer Board of the City of Oxford

PERMIT NUMBER: AL0058408

MAILING ADDRESS: Post Office Box 3663
Oxford, AL36203

MONITORING POINT: 001T

COUNTY:

FACILITY: Oxford Tull C Allen Wwtp

Monitoring Period : 2021-02-01 To: 2021-02-28

NO DISCHARGE FROM SITE: ()

Parameter		Quantity or Loading		Units	Quality or Concentration			Units	No. Ex.	Frequency of Analysis	Sample Type
		****	0		****	****	****				
TOXICITY, CERIODAPHNIA CHRONIC PARAM CODE: 61426 Stage Code: 1 Final Effluent	Sample Measurement	****	0	9A pass(0)/fail(1)	****	****	****		0	See Permit Requirements	24-Hr Composite
	Permit Requirement	****	0 Single Sample		****	****	****			See Permit Requirements	24-Hr Composite
TOXICITY, PIMEPHALES CHRONIC PARAM CODE: 61428 Stage Code: 1 Final Effluent	Sample Measurement	****	0	9A pass(0)/fail(1)	****	****	****		0	See Permit Requirements	24-Hr Composite
	Permit Requirement	****	0 Single Sample		****	****	****			See Permit Requirements	24-Hr Composite
Name/Title of Principal Executive Officer Or Authorized Agent	I CERTIFY UNDER PENALTY OF LAW THAT I HAVE PERSONALLY EXAMINED AND AM FAMILIAR WITH THE INFORMATION SUBMITTED HEREIN AND BASED ON MY INQUIRY OF THOSE INDIVIDUALS IMMEDIATELY RESPONSIBLE FOR OBTAINING THE INFORMATION, I BELIEVE THE SUBMITTED INFORMATION IS TRUE, ACCURATE AND COMPLETE. I AM AWARE THAT THERE ARE SIGNIFICANT PENALTIES FOR SUBMITTING FALSE INFORMATION, INCLUDING THE POSSIBILITY OF FINE AND IMPRISONMENT. SEE 18 U.S.C. § 1001 AND 33 U.S.C. §1319 (Penalties under these statutes may include fines up to \$10,000 and or maximum imprisonment of between 6 months to 5 years.)						Signature of Principal Executive Officer Or Authorized Agent		Telephone No	Date (MM/DD/YY)	

COMMENT AND EXPLANATION OF ANY VIOLATIONS (Reference all attachments here)