Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No:	AL0058408			
Monitoring Period				
From: 10/1/2024	To: 10/31/2024			

Digitally signed by: AEPACS Date: 2024.11.26 09:58:53 -06:00 Reason: Copy Of Record Location: State of Alabama

Outfall: 001-1

Parameter		Quantity of	or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Turbidity (00070)	Sample Measurement	****	****	****	****	1.51	2	NTU	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		0	5X Weekly	Grab
Oxygen, Dissolved (DO) (00300)	Sample Measurement	****	****	****	7.2	****	****	mg/l	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	****			3X Weekly test	Grab
pH (00400)	Sample Measurement	****	****	****	6.69	****	7.39	S.U.	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	6.0 Minimum Daily	****	9.0 Maximum Daily	3.0.	0	3X Weekly test
Solids, Total Suspended (00530)	Sample Measurement	243	276	lbs/day -	****	11.8	16.2	- mg/l		3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	1125 Monthly Average	1688 Weekly Average	105/443	****	30.0 Monthly Average	45.0 Weekly Average		0	3X Weekly test	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	11/26/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From: 10/1/2024	To: 10/31/2024				

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Solids, Total Suspended (00530)	Sample Measurement	4353	9971	- lbs/day -	****	192	375	m c /1		3X Weekly test	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite
Nitrogen, Ammonia Total (As N) (00610)	Sample Measurement	10.22	14.19	lbs/day	****	0.49	0.66	- mg/l		3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	37.5 Monthly Average	56.2 Weekly Average		****	1.0 Monthly Average	1.5 Weekly Average		0	3X Weekly test	24-Hr Composite
Nitrogen, Kjeldahl Total (As N)	Sample Measurement	28	28	lbs/day ·		4	0	Monthly	24-Hr Composite		
(00625) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		***** REPORT REPORT Weekly Average	mg/l		Monthly	24-Hr Composite		
Nitrite Plus Nitrate Total 1 Det.			****	6	6	(1	0	Monthly	24-Hr Composite		
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	- mg/l	U	Monthly	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Meredith Holzer	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 831-5618	11/26/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP **Location:** 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From: 10/1/2024	To: 10/31/2024				

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type				
Phosphorus, Total (As P) (00665)	Sample Measurement	20	20	lbs/day –	****	1.20	1.20	mg/l	0	Monthly	24-Hr Composite				
EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average			Monthly	24-Hr Composite				
Silver Total Recoverable (01079)	Sample Measurement	****	****	****	****	*B	*B	ug/l		Monthly	Grab				
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		0	Monthly	Grab				
Color (ADMI Units) (01290)	Sample Measurement	****	****	****	****	****	****	56	4 DV (I		5X Weekly	Grab			
EFFLÜENT GROSS VALUE	Permit Requirement	****	****			*****		*****		*****	****	****	80 Maximum Daily	ADMI	0
Flow, In Conduit or Thru	Sample Measurement	2.47			****			Daily	Continuous						
Treatment Plant (50050) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****	_ ****	0	Daily	Continuous				

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 831-5618	11/26/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From:	To:				
10/1/2024	10/31/2024				

Parameter		Quantity o	r Loading	Units	Units Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type	
Chlorine, Total Residual (50060) EFFLUENT GROSS VALUE	Sample Measurement	****	****	****	****	*9	*9	mg/l	0	3X Weekly test	Grab
	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily			3X Weekly test	Grab
E. Coli (51040) EFFLUENT GROSS VALUE	Sample Measurement	****	****	****	****	26	72	col/100mL	0	5X Weekly	Grab
	Permit Requirement	****	****		****	126 Monthly Average	298 Maximum Daily			5X Weekly	Grab
Cyanide, Free Available (51173) EFFLUENT GROSS VALUE	Sample Measurement	****	****	- *****	****	*B	*B	ug/I	0	Monthly	Grab
	Permit Requirement	****	****		****	31.4 Monthly Average	70.5 Maximum Daily			Monthly	Grab
Peracetic Acid (51674) EFFLUENT GROSS VALUE	Sample Measurement	****	****	****	****	****	0.14	(1		5X Weekly	Grab
	Permit Requirement	****	****	*****	****	****	1.0 Maximum Daily	mg/l	0	5X Weekly	Grab

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	TELEPHONE NO.	DATE
Meredith Holzer	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	(256) 831-5618	11/26/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No:	AL0058408				
Monitoring Period					
From: 10/1/2024	To: 10/31/2024				

Parameter		Quantity (or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
BOD, Carbonaceous 05 Day,	Sample Measurement	77	114		****	3.7	4.2	- mg/l	0	3X Weekly test	24-Hr Composite
20C (80082) EFFLUENT GROSS VALUE	Permit Requirement	300 Monthly Average	450 Weekly Average	lbs/day	****	8.0 Monthly Average	12.0 Weekly Average			3X Weekly test	24-Hr Composite
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	1649	2563	lbs/day	****	82	95	ma/l	0	3X Weekly test	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average	mg/l		3X Weekly test	24-Hr Composite
BOD, Carb-5 Day, 20 Deg C,	Sample Measurement	****	****	*****	95	****	****	- %	0	Monthly	Calculated
Percent Remvl (80091) Percent Removal	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****			Monthly	Calculated
Solids, Suspended Percent Removal (81011) Percent Removal	Sample Measurement	****	****		91	****	****			Monthly	Calculated
	Permit Requirement	****	****	****	85.0 Monthly Average Minimum	****	****	%	0	Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 831-5618	11/26/2024		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408

Monitoring Period

From: To: 10/1/2024 10/31/2024

END OF REPORT

NAME OF PR	INCIPAL	EXEC	UTIVE
OFFICER OR	AUTHOR	IZED	ACENT

Meredith Holzer

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE	
Electronically Signed via AEPACS	(256) 831-5618	11/26/2024	

Submission Identifier: DMR-AL0058408-20241031-1

Submission Signature Hash: k/kM029/Am9kW2Bk4A15Z8b3B7KJYz6maW0IUPgTOYs=

Submitter Name: Meredith Holzer

Submitter Email: mholzer@oxfordwater.com

Submitted Date/Time: 11/26/2024 9:58:53 AM