Digitally signed by: AEPACS Date: 2023.04.25 10:22:59 -05:00 Reason: Copy Of Record Location: State of Alabama

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408			
Facility Name:	Oxford Tull C. Allen WWTP	Monitorir	ng Period		
Location:	2975 Silver Run Road Oxford, AL 36203	From: 3/1/2023	To: 3/31/2023		
County:	Talladega				

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Turbidity (00070) EFFLUENT GROSS VALUE	Sample Measurement	****	****	****	****	10.26	19.5	NTU	0	5X Weekly	Grab	
	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		0	5X Weekly	Grab	
Oxygen, Dissolved (DO)	Sample Measurement	****	****	****	8.12	****	****	- mg/l	mg/l	0	3X Weekly test	Grab
(00300) EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	****			3X Weekly test	Grab	
рН (00400)	Sample Measurement	****	****	****	6.93	****	7.34	S.U.	0	3X Weekly test	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	9.0 Maximum Daily	3.0.	0	3X Weekly test	Grab	
Solids, Total Suspended (00530) EFFLUENT GROSS VALUE	Sample Measurement	395	637		****	8.4	12.7	— mg/l	0	3X Weekly test	24-Hr Composite	
	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average			3X Weekly test	24-Hr Composite	

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Meredith Holzer	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 831-5618	04/25/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period				
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2023	To: 3/31/2023			

Parameter		Quantity o	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Solids, Total Suspended (00530) RAW SEW/INFLUENT	Sample Measurement	6733	9053	11 / 1	****	149	175	mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average		0	3X Weekly test	24-Hr Composite
Nitrogen, Ammonia Total (As	Sample Measurement	26.13	51.62	lbs/day	****	0.57	1.27	mg/l	0	3X Weekly test	24-Hr Composite
N) (00610) EFFLUENT GROSS VALUE	Permit Requirement	750 Monthly Average	1125 Weekly Average	ibs/day	****	20.0 Monthly Average	30.0 Weekly Average		0	3X Weekly test	24-Hr Composite
Nitrogen, Kjeldahl Total (As N) (00625)	Sample Measurement	192	192	11	***** 3.30 3.30 me/l 0	0	Monthly	24-Hr Composite			
(00023) EFFLUENT GROSS VALUE		REPORT Weekly Average	· lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite	
Nitrite Plus Nitrate Total 1 Det. (As N) (00630) EFFLUENT GROSS VALUE	Sample Measurement	209	209		****	3.6	3.6		0	Monthly	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	TELEPHONE NO.	DATE
Meredith Holzer	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	(256) 831-5618	04/25/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period				
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2023	To: 3/31/2023			

Parameter		Quantity o	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Phosphorus, Total (As P)	Sample Measurement	64	64	11	****	1.10	1.10		0	Monthly	24-Hr Composite
(00665) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite
Silver Total Recoverable	Sample Measurement	****	****	*****	****	*В	*В	- ug/l 0	0	Monthly	Grab
(01079) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		0	Monthly	Grab
Color (ADMI Units) (01290)	Sample Measurement	****	****	****	****	****	51			5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	80 Maximum Daily	ADMI	0	5X Weekly	Grab
Flow, In Conduit or Thru Treatment Plant (50050) EFFLUENT GROSS VALUE	Sample Measurement	5.63	7.33		****	****	****	****	0	Daily	Continuous
	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****		U	Daily	Continuous

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Meredith Holzer	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Electronically Signed via AEPACS	(256) 831-5618	04/25/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period				
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2023	To: 3/31/2023			

Parameter		Quantity o	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Chlorine, Total Residual (50060) EFFLUENT GROSS VALUE	Sample Measurement	****	****	****	****	*9	*9	mg/l	0	3X Weekly test	Grab
	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily		0	3X Weekly test	Grab
E. Coli (51040)	Sample Measurement	****	****	****	****	22	67	- col/100mL	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	548 Monthly Average	2507 Maximum Daily		0	5X Weekly	Grab
Cyanide, Free Available	Sample Measurement	****	****	****	****	*B	*В	4	0	Monthly	Grab
(51173) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	31.4 Monthly Average	70.5 Maximum Daily	ug/l	0	Monthly	Grab
Peracetic Acid (51674)	Sample Measurement	****	****		****	****	0.21	- mg/l	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	****	****	****	1.0 Maximum Daily		0	5X Weekly	Grab

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system,	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Meredith Holzer	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Electronically Signed via AEPACS	(256) 831-5618	04/25/2023

Permittee Name: Water Works & Sewer Board of the City of Oxford		Permit No: AL0058408		
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period		
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2023	To: 3/31/2023	

Parameter		Quantity or Loading		Units	Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type	
BOD, Carbonaceous 05 Day, 20C (80082) EFFLUENT GROSS VALUE	Sample Measurement	166	169	- lbs/day	****	3.5	3.8	mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	938 Monthly Average	1407 Weekly Average		****	25.0 Monthly Average	37.5 Weekly Average			3X Weekly test	24-Hr Composite
BOD, Carbonaceous 05 Day, 20C (80082) RAW SEW/INFLUENT	Sample Measurement	3442	3816	- lbs/day	****	78	82	- mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average			3X Weekly test	24-Hr Composite
BOD, Carb-5 Day, 20 Deg C, Percent Remvl (80091) Percent Removal	Sample Measurement	****	****	****	95	****	****	- %	0	Monthly	Calculated
	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****			Monthly	Calculated
Solids, Suspended Percent Removal (81011) Percent Removal	Sample Measurement	****	****	****	94	****	****	- %	0	Monthly	Calculated
	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****			Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Meredith Holzer		Electronically Signed via AEPACS	(256) 831-5618	04/25/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408		
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period		
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2023	To: 3/31/2023	

END OF REPORT

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Meredith Holzer			(256) 831-5618	04/25/2023

Submission Identifier:DMR-AL0058408-20230331-1Submission Signature Hash:/bo+uQyQ/6wWzVIDVJAnF/MtjIG+IXYIqrnK+GhJFbI=Submitter Name:Meredith HolzerSubmitter Email:mholzer@oxfordwater.com

Submitted Date/Time: 4/25/2023 10:22:59 AM