Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Dame!4 Na.	AL 0050400				
Permit No: AL0058408					
Monitoring Period					
From: To:					
5/1/2022	5/31/2022				

Digitally signed by: GlobalSign RSA OV SSL CA 2018 Date: 2022.06.27 09:27:42 -05:00 Reason: Copy Of Record Location: State of Alabama

#### Outfall: 001-1

Parameter		Quantity or Loading		Units	Units Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type	
Turbidity (00070)	Sample Measurement	****		****	****	2.4	5.63	NTU		5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	REPORT Monthly Average	REPORT Maximum Daily		0	5X Weekly	Grab
Oxygen, Dissolved (DO) (00300)	Sample Measurement	****	****	****	7.9	****	*****	mg/l	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	****	mg/l	0	3X Weekly test	Grab
pH (00400)	Sample Measurement	****	****	****	7.23	****	7.67	S.U.	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	9.0 Maximum Daily		0	3X Weekly test	Grab
Solids, Total Suspended	Sample Measurement	292	465		****	10.4	19.3	- mg/l	0	3X Weekly test	24-Hr Composite
(00530) EFFLUENT GROSS VALUE	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average			3X Weekly test	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE	E
OFFICER OR AUTHORIZED AGEN	Т

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE			
Electronically Signed via AEPACS	(256) 405-6821	06/27/2022			

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

**Outfall: 001-1** 

Permit No: AL0058408					
Monitoring Period					
From:	To:				
5/1/2022	5/31/2022				

Parameter		Quantity (	Quantity or Loading Units		Units Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type	
Solids, Total Suspended (00530)	*		****	337	426		0	3X Weekly test	24-Hr Composite		
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	U	3X Weekly test	24-Hr Composite
Nitrogen, Ammonia Total (As N) (00610)	Sample Measurement	*B	*B	lbs/day	****	*B	*B			3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	37.5 Monthly Average	56.2 Weekly Average	ios/day	****	1.0 Monthly Average	1.5 Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite
Nitrogen, Kjeldahl Total (As N) (00625)	Sample Measurement	56	56	lbs/day	****	2.2	2.2	mg/l	0	Monthly	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	ios/day	****	REPORT Monthly Average	REPORT Weekly Average		0	Monthly	24-Hr Composite
Nitrite Plus Nitrate Total 1 Det.	Sample Measurement	94	94	11/4	****	3.7	3.7			Monthly	24-Hr Composite
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE			
Electronically Signed via AEPACS	(256) 405-6821	06/27/2022			

Max Gaskins

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

**Outfall: 001-1** 

Permit No: AL0058408					
Monitoring Period					
<b>From:</b> 5/1/2022	<b>To:</b> 5/31/2022				

Parameter		Quantity (	or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Phosphorus, Total (As P)	Sample Measurement	21	21			****	0.81	0.81	m c /1	0	Monthly	24-Hr Composite
(00665) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	U	Monthly	24-Hr Composite	
Silver Total Recoverable (01079)	Sample Measurement	****	****	****	****	*B	*B		0	Monthly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily	ug/l		Monthly	Grab	
Color (ADMI Units) (01290)	Sample Measurement	****	****	****	****	****	68	A DV G	0	5X Weekly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	****	80 Maximum Daily	ADMI		5X Weekly	Grab	
Flow, In Conduit or Thru	Sample Measurement	3.38	6.33	MGD	****	****	****	****	0	Daily	Continuous	
Treatment Plant (50050) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****		0	Daily	Continuous	

NAME OF PRINCIPAL EXECUTI	VE
OFFICER OR AUTHORIZED AGE	NT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 405-6821	06/27/2022		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408						
Maria Maria Maria Maria						
Monitoring Period						
From:	To:					
5/1/2022	5/31/2022					

Parameter		Quantity of	r Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Chlorine, Total Residual (50060)	Sample Measurement	****	****	****	****	*9	*9	mg/l		3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily		0	3X Weekly test	Grab
E. Coli (51040)	Sample Measurement	****	****	****	****	26	117		0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	126 Monthly Average	298 Maximum Daily	col/100mL		5X Weekly	Grab
Cyanide, Free Available	Sample Measurement	****	****	****	****	*B	*B	4	0	Monthly	Grab
(51173) EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	31.4 Monthly Average	70.5 Maximum Daily	ug/l		Monthly	Grab
Peracetic Acid (51674)	Sample Measurement	****	*****	****	****	0.20			5X Weekly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	****	1.0 Maximum Daily	mg/l	0	5X Weekly	Grab

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 405-6821	06/27/2022		

Permittee Name: Water Works & Sewer Board of the City of Oxford

**Facility Name:** Oxford Tull C. Allen WWTP **Location:** 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

**Outfall: 001-1** 

Permit No: AL0058408					
Monitoring Period					
To:					
5/31/2022					
3,3 ., _022					

Parameter		Quantity (	or Loading	Units	Qual	ity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	116	167 ***** 4.1 4.4	4.4		0	3X Weekly test	24-Hr Composite				
EFFLUENT GROSS VALUE	Permit Requirement	300 Monthly Average	450 Weekly Average	lbs/day	****	8.0 Monthly Average	12.0 Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite	
BOD, Carbonaceous 05 Day,	Sample Measurement	2194	2899	11 / 1	****	75	78	mg/l	_		3X Weekly test	24-Hr Composite
20C (80082) RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average		0	3X Weekly test	24-Hr Composite	
BOD, Carb-5 Day, 20 Deg C,	Sample Measurement	****	****	****	94	****	****	%	0	Monthly	Calculated	
Percent Remvl (80091) Percent Removal	Permit Requirement	****	****	****	85.0 Monthly Average Minimum	****	****			Monthly	Calculated	
Solids, Suspended Percent	Sample Measurement	****	****	****	96	****	****			Monthly	Calculated	
Removal (81011) Percent Removal	Permit Requirement	****	****	*****	85.0 Monthly Average Minimum	****	****	%	0	Monthly	Calculated	

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 405-6821	06/27/2022

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408						
Monitoring Period						
From:	To:					
5/1/2022	5/31/2022					

#### Outfall: 001-T

Parameter		Quantity or Loading		Units Quality or Concentration		ity or Loading Units Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type
Toxicity, Ceriodaphnia Chronic	Sample Measurement	****	*9	O.f.:1_1	****	****	****	****		See Permit Requirements	24-Hr Composite
(61426) EFFLUENT GROSS VALUE	Permit Requirement	****	0 Single Sample	pass=0;fail=1	****	****	****	****	0	See Permit Requirements	24-Hr Composite
Toxicity, Pimephales Chronic	Sample Measurement	****	*9	pass=0;fail=1	****	****	****	****	0	See Permit Requirements	24-Hr Composite
(61428) EFFLUENT GROSS VALUE	Permit Requirement	****	0 Single Sample	pass=0;1an=1	****	****	****			See Permit Requirements	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 405-6821	06/27/2022

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408

Monitoring Period

From: To: 5/1/2022 5/31/2022

END OF REPORT

NAME OF PRINCIPAL EXE	CUTIVE
OFFICER OR AUTHORIZED	ACENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 405-6821	06/27/2022

**Submission Identifier:** DMR-AL0058408-20220531-1

**Submission Signature Hash:** fvBO/G02edtSuaPDc5gkHPuV9jvjEmPAF242zt4EFDI=

**Submitter Name:** Max Gaskins

**Submitter Email:** mgaskins@oxfordwater.com

**Submitted Date/Time:** 6/27/2022 9:27:41 AM