



600 Barry Street
Post Office Box 3663
Oxford, Alabama 36203

Definitions You Need To Know

Non-Detects (ND) - Laboratory analysis indicates that the constituent is not present.

Parts per million (ppm) or Milligrams per liter (mg/l) - One part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - One part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter - One part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter - One part per quadrillion corresponds to one minute in 2,000,000,000 years, or a single penny in \$10,000,000,000,000.

Picocuries per liter (pCi/l) - Picocuries per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Millirems per year (mrem/yr) - Million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU) - Nephelometric turbidity unit is a measure of the clarity of the water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Variations & Exemptions (V&E) - State or EPA permission not to meet an MCL or a treatment technique under certain conditions.

Action Level - The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT) - A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL) - The "Maximum Allowed" is the highest level of a contaminant that is allowed in drinking water. MCL's are set as close to the MCLG's as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG) - The "Goal" is the level of contaminant in drinking water below which there is no known or expected risk of health. MCLG's allow for margin of safety.

STANDARD LIST OF PRIMARY DRINKING WATER CONTAMINANTS			
Contaminant	MCL	Unit	MCL
Bacteriological			
Total Coliform Bacteria	<5%	present or absent	600
Fecal Coliform & E. Coli	0	present or absent	75
Turbidity	TT	NTU	5
Nitrate			1
Biochemical			
Beta/photom emitters	4	mrem/yr	50
Alpha emitters	15	pCi/l	2
Combined radium	5	pCi/l	50
Uranium	30	pCi/l	2
Inorganic Chemicals			
Antimony	6	ppb	70
Arsenic	10	ppb	50
Asbestos	7	MFL	TT
Barium	2	ppm	2
Beryllium	4	ppb	200
Cadmium	5	ppb	40
Chromium	100	ppb	200
Copper	AL=1.3	ppm	400
Cyanide	200	ppb	6
Fluoride	4	ppm	7
Lead	AL=15.0	ppb	20
Mercury	2	ppb	30
Nitrate	10	ppm	4
Endothal	100	ppb	1
Endrin	2	ppb	60
Epiclorohydrin	TT		7
Glyphosate	700	ppb	70
Heptachlor	400	Nanogram/l	100
Heptachlor epoxide	200	Nanogram/l	5
Hexachlorobenzene	1	ppb	700
Hexachlorocyclopentadiene	50	ppb	50
Lindane	200	Nanogram/l	100
Methoxychlor	40	ppb	5
Oxamyl (Vydate)	200	ppb	5
Pentachlorophenol	1	ppb	200
Picloram	500	ppb	5
Simazine	4	ppb	80
Toxaphene	3	ppb	1
Benzene	5	ppb	2
Carbon tetrachloride	5	ppb	10
Chlorobenzene	100	ppb	4
Dibromochloropropane	200	ppt	800
Bromate			10
UNREGULATED CONTAMINANTS			
1,1-Dichloroethene	Bromochloroethane	Metolachlor	Dieldrin
1,1,1,2-Tetrachloroethane	Bromofom	Metribuzin	Hexachlorobutadiene
1,1,2,2-Tetrachloroethane	Bromomethane	N-Butylbenzene	Isopropylbenzene
1,1-Dichloroethane	Butachlor	Naphthalene	M-Dichlorobenzene
1,2,3-Trichlorobenzene	Carbaryl	N-Propylbenzene	Methomyl
1,2,3-Trichloropropane	Chloroethane	O-Chlorotoluene	MTBE
1,2,4-Trimethylbenzene	Chloroform	P-Chlorotoluene	Metolachlor
1,3-Dichloropropane	Chloromethane	P-Isopropyltoluene	Metribuzin
1,3-Dichloropropane	Dibromochloromethane	Propachlor	N-Butylbenzene
1,3,5-Trimethylbenzene	Dibromomethane	Sec-Butylbenzene	Naphthalene
2,2-Dichloropropane	Dicamba	Tert-Butylbenzene	N-Propylbenzene
3-Hydroxycarboran	Dichlorodifluoromethane	Trichlorofluoromethane	O-Chlorotoluene
Aldicarb	Dieldrin	Chloroform	P-Chlorotoluene
Aldicarb Sulfone	Hexachlorobutadiene	Chloromethane	P-Isopropyltoluene
Aldicarb Sulfoxide	Isopropylbenzene	Dibromochloromethane	Propachlor
Aldrin	M-Dichlorobenzene	Dibromomethane	Sec-Butylbenzene

OUR DAILY WATER

If you have any questions about this report or concerning your water utility, please contact our main office. We want our valued customers to be informed about their water utility.

Oxford Water Works & Sewer Board
600 Barry Street, Post Office Box 3663
Oxford, Alabama 36203

Phone: 256-831-5618
Fax: 256-831-9063

Main Office Hours: 7:00 a.m. to 4:30 p.m. Monday - Friday
Water Board Meets Wednesday of each month at 12:00 p.m.

General Manager.....Wayne Livingston
Controller.....Patrick Prater
Engineer.....Meredith Holzer

2008 Annual Water Quality Report

Information about your water services from
Oxford Water Works & Sewer Board

Oxford Water Works & Sewer Board is pleased to present to you this year's 2008 Annual Water Quality Report. This report is designed to inform you about the quality water and service we deliver to you on a daily basis, and our constant goal being to provide you with a safe and dependable supply of drinking water.

BANK DRAFT IS AVAILABLE FROM OXFORD WATER!

Saves you Time - Postage - Checks

Contact our office at 831-5618 for more information.

THE OXFORD WATER & SEWER SYSTEM INCLUDES:

Water Mains in Service.....	306 miles
Sewer Mains in Service.....	118 miles
Water Storage Tanks.....	5
Water Storage Capacity.....	5.4 Million Gallons
Water Production Capacity.....	9.0 Million Gallons Per Day
Booster Pumping Stations.....	5
Public Fire Hydrants.....	700
Sewer Treatment Capacity.....	6.4 Million Gallons Per Day
Sewer Pumping Stations.....	27
Metered Connections.....	9675

WHERE DOES OUR WATER COME FROM?

Oxford's Water Supply is classified as Groundwater. Groundwater classification means the water is pumped from below the surface of the ground.

Drinking water is supplied to customers of Oxford Water by five production wells that draw water from The Knox Group, Shady Dolomite Aquifer. Each well is approximately 300 feet deep and the water from each well meets all regulations without any treatment required; however, we do add some chlorine to protect the water in tanks and distribution lines.

Oxford Water Works & Sewer Board is a member of American Water Works Association (AWWA), Alabama Rural Water Association (ARWA), the National Rural Water Association (NRWA), Alabama's Water Environment Association (AWEA), and the Groundwater Foundation.

The Oxford Water Works routinely monitors for constituents in your drinking water. We had tests performed for over 90 constituents and only 9 were at detectable levels. All monitoring and testing were performed according to Federal and State Laws. This table shows the results of our monitoring for the period of January 1, 2008 to December 31, 2008 for Microbiological, Radioactive, Inorganic, Lead/Copper, Nitrates, Synthetic Organics

(including pesticides and herbicides), Disinfection By-Products, and Volatile Organic Contaminants. All of these were performed in accordance with the regulatory schedule.

As you can see by the table, our system had no violations. We are proud that your drinking water meets or exceeds all Federal and State requirements. We have learned through our monitoring and testing that some constituents have been detected. The EPA has determined that your water IS SAFE at these levels. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Thank you for allowing us to continue providing your family with clean quality water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. These improvements are sometimes reflected as rate structure adjustments. Thank you for your understanding. Please call our office if you have any questions.

Safe Drinking Water Act


What does this mean for you?

The Safe Drinking Water Act (SDWA) was signed into law on December 16, 1974. The purpose of the law is to assure that the nation's water supply systems serving the public meet the minimum national standards for the protection of public health.

The SDWA covers all public water systems with piped water for human consumption with at least 15 service connections or a system that regularly serves at least 25 individuals. The SDWA directed the U.S. Environmental Protection Agency (EPA) to establish national drinking water standards. These standards limit the amount of certain contaminants provided by public water. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water. All drinking water, including bottled water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at 1-800-426-4791. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infection. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline at 1-800-426-4791.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and radioactive material, and it can pick up substances resulting from the presence of animals or from human activities.



Lead and Copper Compliance

The most recent testing for lead and copper compliance within the distribution system was in 2007. This testing was done in accordance with applicable regulations. No lead or copper samples exceeded the action level. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Oxford Water Works and Sewer Board is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods and other steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/scjewater/lead>.

Monitoring Schedule

Constituent Monitored	Date Monitored
Inorganic Contaminants	2007
Lead/Copper	2007
Microbiological Contaminants	Current
Nitrates	2008
Radioactive Contaminants	2007
Synthetic Organic Contaminants (incl. pesticides & herbicides)	2007
Volatile Organic Contaminants	2008
Disinfection By-Products	2008

TABLE OF DETECTED DRINKING WATER CONTAMINANTS

Contaminants	Violation (Yes/No)	Level Detected	Unit of Measurement	MCL G	MCL	Likely Source of Contamination
Copper	No	0.165* (0>AL)	ppm	1.3	AL = 1.3	Corrosion of household plumbing systems, erosion of natural deposits, leaching from wood preservatives
Nitrate (as Nitrogen)	No	0.95 (0.49 - 0.95)	ppm	10	10	Runoff from fertilizer use, leaching from septic tanks, sewage; erosion of natural deposits
Trichloroethylene	No	2.88 (ND - 2.88)	ppb		5	Discharge from metal degreasing sites and other factories
Secondary Contaminants						
Chloride	No	Avg 3.16 (2.30 - 4.34)	ppm	N/A	250	Naturally occurring in the environment or as a result of industrial discharge or agricultural runoff
Hardness	No	Avg 126 (104 - 146)	ppm	N/A	-	Naturally occurring in the environment or as a result of treatment with water additives
Iron	No	Avg 0.05 (ND - 0.13)	ppm	N/A	0.30	Naturally occurring in the environment; erosion of natural deposits; leaching from pipes
pH	No	Avg 7.85 (7.62 - 8.04)	S.U.	N/A	N/A	Naturally occurring in the environment or as a result of treatment with water additives
Sulfate	No	Avg 2.57 (1.48 - 6.26)	ppm	N/A	250	Naturally occurring in the environment or as a result of industrial discharge or agricultural runoff
Total Dissolved Solids	No	Avg 137 (108 - 168)	ppm	N/A	500	Naturally occurring in the environment or as a result of industrial discharge or agricultural runoff

CALENDAR YEAR 2008
CONSUMER CONFIDENCE REPORT
CERTIFICATION FORM

Water System Name: Oxford Water Works & Sewer Board

PWSID No.: PW0000162

I affirm that the attached Consumer Confidence Report (CCR) for the above referenced Public Water System has been distributed to customers, and the appropriate notices of availability have been given, in accordance with ADEM Administrative Code R 335-7-14. The information contained in the CCR is correct and consistent with the compliance monitoring data previously submitted to ADEM.

Furthermore, if drinking water was supplied to other Public Water System(s) for more than 60 consecutive days during the year, a copy of the applicable compliance monitoring data was mailed or supplied to the purchasing system(s) on the following date:

APRIL 2009

Certified by: Signature:



Print Name: MEREIDITH HOLZER

Title: ENGINEER

Phone #: 256-831-5618

Date: 06/15/2009

U.S. Postal Service
CERTIFIED MAIL RECEIPT
(Domestic Mail Only; No Insurance Coverage Provided)

For delivery information visit our website at www.usps.com

7009 0820 0001 1531 6665
MONTGOMERY AL 36130
OFFICIAL USE

Postage	\$	\$0.61	0554
Certified Fee		\$2.80	08
Return Receipt Fee (Endorsement Required)		\$2.30	Postmark Here
Restricted Delivery Fee (Endorsement Required)		\$0.00	
Total Postage & Fees	\$	\$5.71	06/16/2009

Sent To
ADEM AHN Laura Taylor
Street, Apt. No.
or PO Box No. POBOX 301463
City, State, ZIP+4
MONTGOMERY, AL 36130 1063
See Reverse for Instructions

OXFORD BRANCH
OXFORD, Alabama
362039998
0107830554-0097
(256)831-3515
06/16/2009 02:32:02 PM

Product Description	Sales Receipt		Final Price
	Sale Qty	Unit Price	

MONTGOMERY AL 36130
Zone-2 First-Class \$0.61

Letter
1.20 oz. Return Rcpt (Green Card) \$2.30

Certified \$2.80
Label #: 70090820000115316665

Issue PVI: \$5.71
=====

Total: \$5.71

Paid by: Cash \$10.00
Change Due: -\$4.29

Order stamps at USPS.com/shop or call
1-800-Stamps24. Go to USPS.com/clicknship
to print shipping labels with postage.
For other information call 1-800-ASK-USPS.

Bill#: 1000302537914
Clerk: 08

All sales final on stamps and postage
Refunds for guaranteed services only
Thank you for your business

HELP US SERVE YOU BETTER

Go to: <http://gx.gallup.com/pos>
TELL US ABOUT YOUR RECENT
POSTAL EXPERIENCE

YOUR OPINION COUNTS

SENDER: COMPLETE THIS SECTION

- Complete items 1, 2, and 3. Also complete item 4 if Restricted Delivery is desired.
- Print your name and address on the reverse so that we can return the card to you.
- Attach this card to the back of the mailpiece, or on the front if space permits.

1. Article Addressed to:

ADEM
 ATTN: Laura Taylor
 1400 Coliseum Blvd.
 P.O. Box 301463
 Montgomery, AL 36130
 1463

2. Article Number

(Transfer from service label)

7009 0820 0001 1531 6665

COMPLETE THIS SECTION ON DELIVERY

A. Signature

X *[Signature]* Agent
 Addressee

B. Received by (Printed Name)

C. Date of Delivery

D. Is delivery address different from item 1? Yes
 If YES, enter delivery address below: No

3. Service Type


- Certified Mail Express Mail
- Registered Return Receipt for Merchandise
- Insured Mail C.O.D.

4. Restricted Delivery? (Extra Fee)

Yes



UNITED STATES POSTAL SERVICE



First-Class Mail
Postage & Fees Paid
USPS
Permit No. G-10

• Sender: Please print your name, address, and ZIP+4 in this box •

OXFORD WATER WORKS + SEWER BD
P.O. Box 3663
OXFORD, AL 36203

