Digitally signed by: AEPACS Date: 2023.02.21 11:49:39 -06:00 Reason: Copy Of Record Location: State of Alabama

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408			
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period			
Location:	2975 Silver Run Road Oxford, AL 36203	From: 1/1/2023	To: 1/31/2023		
County:	Talladega				

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Turbidity (00070)	Sample Measurement	****	****	****	****	8.76	34.10	NTU	0	5X Weekly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		0	5X Weekly	Grab	
Oxygen, Dissolved (DO)	Sample Measurement	****	****	****	6.83	****	****	- mg/l		0	3X Weekly test	Grab
(00300) EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	6.0 Minimum Daily	****	****			3X Weekly test	Grab	
рН (00400)	Sample Measurement	****	****	****	7.09	****	7.51	S.U.	0	3X Weekly test	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	9.0 Maximum Daily	5.0.	0	3X Weekly test	Grab	
Solids, Total Suspended	Sample Measurement	569	1303	lbs/day.	****	12.3	23.3		0	3X Weekly test	24-Hr Composite	
(00530) EFFLUENT GROSS VALUE	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average	- mg/l	0	3X Weekly test	24-Hr Composite	

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Electronically Signed via AEPACS	(256) 405-6821	02/21/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period				
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 1/1/2023	To: 1/31/2023			

Parameter		Quantity o	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Solids, Total Suspended (00530)	Sample Measurement	12281	24301	11 / 1	****	230	429	mg/l	0	3X Weekly test	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	ing/i	0	3X Weekly test	24-Hr Composite
Nitrogen, Ammonia Total (As	Sample Measurement	61	207.38	lbs/day.	****	1.11	3.61	- mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	750 Monthly Average	1125 Weekly Average	lbs/day	****	20.0 Monthly Average	30.0 Weekly Average		0	3X Weekly test	24-Hr Composite
Nitrogen, Kjeldahl Total (As N) (00625)	Sample Measurement	64	64	11	****	1.10	1.10		0	Monthly	24-Hr Composite
(00023) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite
Nitrite Plus Nitrate Total 1 Det.	Sample Measurement	88	88	11 /	****	1.50	1.50		0	Monthly	24-Hr Composite
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system,	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Electronically Signed via AEPACS	(256) 405-6821	02/21/2023

Permittee Name: Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name: Oxford Tull C. Allen WWTP	Monitoring Period				
Location: 2975 Silver Run Road Oxford, AL 36203 County: Talladega	From: 1/1/2023	To: 1/31/2023			

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type				
Phosphorus, Total (As P) (00665) EFFLUENT GROSS VALUE	Sample Measurement	9	9	11-5 (4	****	0.15	0.15		0	Monthly	24-Hr Composite				
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite				
Silver Total Recoverable	Sample Measurement	****	****	****	****	*В	*В	- ug/l	a	a	a	ug/l	0	Monthly	Grab
(01079) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		0	Monthly	Grab				
Color (ADMI Units) (01290)	Sample Measurement	****	****	****	****	****	70	ADMI	0	5X Weekly	Grab				
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	80 Maximum Daily	ADMI	0	5X Weekly	Grab				
Flow, In Conduit or Thru	Sample Measurement	5.57	5.57	MGD	****	****	****	****	0	Daily	Continuous				
Treatment Plant (50050) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****		0	Daily	Continuous				

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 405-6821	02/21/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Dxford Permit No: AL0058408			
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period			
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 1/1/2023	To: 1/31/2023		

Parameter		Quantity o	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type			
Chlorine, Total Residual (50060) EFFLUENT GROSS VALUE	Sample Measurement	****	****	****	****	*9	*9		0	3X Weekly test	Grab			
	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily	- mg/l	0	3X Weekly test	Grab			
E. Coli (51040)	Sample Measurement	****	****	****	****	20	72	- col/100mL	1/100 1		1/100mJ	col/100mL 0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	548 Monthly Average	2507 Maximum Daily		0	5X Weekly	Grab			
Cyanide, Free Available (51173)	Sample Measurement	****	****	****	****	*B	*В		0	Monthly	Grab			
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	31.4 Monthly Average	70.5 Maximum Daily	ug/l	0	Monthly	Grab			
Peracetic Acid (51674)	Sample Measurement	****	****	****	****	****	0.22		0	5X Weekly	Grab			
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	1.0 Maximum Daily	mg/l	0	5X Weekly	Grab			

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 405-6821	02/21/2023

Permittee Name: Water Works & Sewer Board of the City of O	Pxford Permit No:	AL0058408
Facility Name: Oxford Tull C. Allen WWTP	Monitorir	ng Period
Location: 2975 Silver Run Road Oxford, AL 36203 County: Talladega	From: 1/1/2023	To: 1/31/2023

Parameter		Quantity or Loading		Units	Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type	
BOD, Carbonaceous 05 Day, 20C (80082) EFFLUENT GROSS VALUE	Sample Measurement	164	186	bs/day	****	3.5	4.1	mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	938 Monthly Average	1407 Weekly Average		****	25.0 Monthly Average	37.5 Weekly Average			3X Weekly test	24-Hr Composite
BOD, Carbonaceous 05 Day, 20C (80082) RAW SEW/INFLUENT	Sample Measurement	3706	4175	lbs/day	****	76	82	- mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average			3X Weekly test	24-Hr Composite
BOD, Carb-5 Day, 20 Deg C, Percent Remvl (80091) Percent Removal	Sample Measurement	****	****	****	95	****	****	- %	0	Monthly	Calculated
	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****			Monthly	Calculated
Solids, Suspended Percent Removal (81011) Percent Removal	Sample Measurement	****	****	****	92	****	****	- %	0	Monthly	Calculated
	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****			Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		TELEPHONE NO.	DATE
Max Gaskins		(256) 405-6821	02/21/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408		
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period		
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 1/1/2023	To: 1/31/2023	

END OF REPORT

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins			(256) 405-6821	02/21/2023

Submission Identifier:DMR-AL0058408-20230131-1Submission Signature Hash:xqU664a+JwNKMe0LRY/HoguEGk5r/SWhGJdHSLkCPJk=Submitter Name:Max GaskinsSubmitter Email:mgaskins@oxfordwater.com

Submitted Date/Time: 2/21/2023 11:49:39 AM