Digitally signed by: GlobalSign RSA OV SSL CA 2018 Date: 2022.04.20 12:44:22 -05:00 Reason: Copy Of Record Location: State of Alabama

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No:	Permit No: AL0058408		
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period			
Location:	2975 Silver Run Road Oxford, AL 36203	From: 3/1/2022	To: 3/31/2022		
County:	Talladega				

Parameter		Quantity o	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Turbidity (00070)	Sample Measurement	****	****	****	****	2.81	4.13	NTU	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily	NIU	0	5X Weekly	Grab
Oxygen, Dissolved (DO)	Sample Measurement	****	****	***** 6.92 ***** 6.0 Minimum Daily	****	****		0	3X Weekly test	Grab	
(00300) EFFLUENT GROSS VALUE	Permit Requirement	****	****			****	****	- mg/l	0	3X Weekly test	Grab
рН (00400)	Sample Measurement	****	****	****	6.48	****	7.49	S.U.	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	9.0 Maximum Daily	5.0.		3X Weekly test	Grab
Solids, Total Suspended (00530) EFFLUENT GROSS VALUE	Sample Measurement	459	611		****	8.5	12.3	- mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average		U	3X Weekly test	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Electronically Signed via AEPACS	(256) 405-6821	04/20/2022

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period				
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2022	To: 3/31/2022			

Parameter		Quantity of	Quantity or Loading		Qua	Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type
Solids, Total Suspended (00530)	Sample Measurement	11189	15120	11	****	208	299	mg/l	0	3X Weekly test	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average		0	3X Weekly test	24-Hr Composite
Nitrogen, Ammonia Total (As N) (00610)	Sample Measurement	41.68	92.65	lbs/day	****	0.77	1.66			3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	750 Monthly Average	1125 Weekly Average		****	20.0 Monthly Average	30.0 Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite
Nitrogen, Kjeldahl Total (As N)	Sample Measurement	109	109	11 / 1	****	2.2	2.2		Monthly	24-Hr Composite	
(00023) EFFLUENT GROSS VALUE	Permit	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite
Nitrite Plus Nitrate Total 1 Det.	Sample Measurement	94	94	11	****	1.9	1.9		0	Monthly	24-Hr Composite
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 405-6821	04/20/2022

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period				
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2022	To: 3/31/2022			

Parameter		Quantity or Loading		Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Phosphorus, Total (As P) (00665) EFFLUENT GROSS VALUE	Sample Measurement	16	16	lbs/day	****	0.33	0.33		0	Monthly	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	105/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite
Silver Total Recoverable	Sample Measurement	****	****	****	****	*В	*В	- ug/l		Monthly	Grab
(01079) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		0	Monthly	Grab
Color (ADMI Units) (01290)	Sample Measurement	****	****	****	****	****	62		0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	80 Maximum Daily	ADMI	0	5X Weekly	Grab
Flow, In Conduit or Thru	Sample Measurement	6.47	8.92		****	****	****	****	0	Daily	Continuous
Treatment Plant (50050) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****			Daily	Continuous

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Electronically Signed via AEPACS	(256) 405-6821	04/20/2022

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period				
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2022	To: 3/31/2022			

Parameter		Quantity or Loading		Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Chlorine, Total Residual (50060) EFFLUENT GROSS VALUE	Sample Measurement	****	****	****	****	*9	*9	mg/l	0	3X Weekly test	Grab
	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily	_	0	3X Weekly test	Grab
E. Coli (51040)	Sample Measurement	****	****	****	****	16	56	- col/100mL	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	548 Monthly Average	2507 Maximum Daily		0	5X Weekly	Grab
Cyanide, Free Available (51173)	Sample Measurement	****	****	****	****	*B	*В		0	Monthly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	31.4 Monthly Average	70.5 Maximum Daily	ug/l	0	Monthly	Grab
Peracetic Acid (51674) EFFLUENT GROSS VALUE	Sample Measurement	****	****	****	****	****	0.19		0	5X Weekly	Grab
	Permit Requirement	****	****		****	****	1.0 Maximum Daily	mg/l	0	5X Weekly	Grab

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Electronically Signed via AEPACS	(256) 405-6821	04/20/2022

Permittee Name: Water Works & Sewer Board of the City of Oxford		Permit No: AL0058408		
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period		
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 3/1/2022	To: 3/31/2022	

Parameter		Quantity or Loading		Units	Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type	
BOD, Carbonaceous 05 Day, 20C (80082) EFFLUENT GROSS VALUE	Sample Measurement	205	246	- lbs/day	****	3.8	3.9	mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	938 Monthly Average	1407 Weekly Average		****	25.0 Monthly Average	37.5 Weekly Average			3X Weekly test	24-Hr Composite
BOD, Carbonaceous 05 Day, 20C (80082) RAW SEW/INFLUENT	Sample Measurement	4130	4748	- lbs/day	****	76	79	mg/l	0	3X Weekly test	24-Hr Composite
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average			3X Weekly test	24-Hr Composite
BOD, Carb-5 Day, 20 Deg C, Percent Remvl (80091) Percent Removal	Sample Measurement	****	****	****	95	****	****	- %	0	Monthly	Calculated
	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****			Monthly	Calculated
Solids, Suspended Percent Removal (81011) Percent Removal	Sample Measurement	****	****	****	95	****	****	- %	0	Monthly	Calculated
	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****			Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins			(256) 405-6821	04/20/2022

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408		
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period		
Location:	2975 Silver Run Road Oxford, AL 36203	From: 3/1/2022	To: 3/31/2022	
County:	Talladega			

END OF REPORT

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins			(256) 405-6821	04/20/2022

Submission Identifier:DMR-AL0058408-20220331-1Submission Signature Hash:F/+T9sxfV5ECo0cRijtkV6ckUwzalk3rqBwNmBAdnn4=Submitter Name:Max GaskinsSubmitter Email:mgaskins@oxfordwater.com

Submitted Date/Time: 4/20/2022 12:44:22 PM