Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408				
Monitoring Period				
To:				
3/31/2024				

Digitally signed by:
AEPACS
Date: 2024.04.24 13:21:29 -05:00
Reason: Copy Of Record
Location: State of Alabama

Outfall: 001-1

Parameter		Quantity of	or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Turbidity (00070)	Sample Measurement	****	****	****	****	2.68	4.79	NTU		7X Monthly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily	NIU	0	5X Weekly	Grab
Oxygen, Dissolved (DO) (00300)	Sample Measurement	****	****	****	7.79	****	****	ma/l	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	****	mg/l		3X Weekly test	Grab
pH (00400)	Sample Measurement	****	****	****	6.98	****	7.58	S.U.	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	6.0 Minimum Daily	****	9.0 Maximum Daily	S.U.	0	3X Weekly test	Grab
Solids, Total Suspended	Sample Measurement	403	688	lha/day	****	9.9	12.5	ma/1	0	3X Weekly test	24-Hr Composite
(00530) EFFLUENT GROSS VALUE	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average	- mg/l	0	3X Weekly test	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 405-6821	04/24/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From:	To:				
3/1/2024	3/31/2024				

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Solids, Total Suspended	Sample Measurement	7196	10492	lho/day:	****	170	279	m c /1	0	3X Weekly test	24-Hr Composite	
(00530) RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite	
Nitrogen, Ammonia Total (As N) (00610)	Sample Measurement	175	372	lhe/day	****	4.05	8.19	ma/l	0	3X Weekly test	24-Hr Composite	
EFFLUENT GROSS VALUE	Permit Requirement	750 Monthly Average	1125 Weekly Average	lbs/day	****	20.0 Monthly Average	30.0 Weekly Average	mg/l	U	3X Weekly test	24-Hr Composite	
Nitrogen, Kjeldahl Total (As N)	Sample Measurement	372	372		11. /1	****	6.3	6.3	4		Monthly	24-Hr Composite
(00625) EFFLUENT GROSS VALUE	Permit REPORT REPORT Requirement Monthly Average Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite			
Nitrite Plus Nitrate Total 1 Det.	Sample Measurement	171	171	11/-1	****	2.9	2.9	(1	0	Monthly	24-Hr Composite	
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite	

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system,	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	(256) 405-6821	04/24/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408				
Monitoring Period				
From:	To:			
3/1/2024	3/31/2024			

Parameter		Quantity (or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type	
Phosphorus, Total (As P)	Sample Measurement	124	124		****	2.1	2.1	m c /l	0	Monthly	24-Hr Composite	
(00665) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	U	Monthly	24-Hr Composite	
Silver Total Recoverable (01079)	Sample Measurement	****	****	****	****	*B	*B	no/l	0	Monthly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	REPORT Monthly Average	REPORT Maximum Daily	ug/l	U	Monthly	Grab	
Color (ADMI Units) (01290)	Sample Measurement	****	****	****		****	****	69	ADMI		5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	80 Maximum Daily	ADMI	0	5X Weekly	Grab	
Flow, In Conduit or Thru	Sample Measurement	4.87	7.31	MCD	****	****	*****	***		Daily	Continuous	
Treatment Plant (50050) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****	. *****	0	Daily	Continuous	

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 405-6821	04/24/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From: 3/1/2024	To: 3/31/2024				
3/ 1/202 4	0/01/2024				

Parameter		Quantity (or Loading	Units	Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type	
Chlorine, Total Residual	Sample Measurement	****	****	****	****	*9	*9	- mg/l	0	3X Weekly test	Grab
(50060) EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	0.066 Monthly Average	0.115 Maximum Daily			3X Weekly test	Grab
E. Coli (51040)	Sample Measurement	****	****	****	16	56	1/100 7		5X Weekly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	548 Monthly Average	2507 Maximum Daily	col/100mL	0	5X Weekly	Grab
Cyanide, Free Available (51173)	Sample Measurement	****	****	- *****	****	*B	*B	ug/l	0	Monthly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	31.4 Monthly Average	70.5 Maximum Daily			Monthly	Grab
Peracetic Acid (51674)	Sample Measurement	****	****	****	****	****	0.21	- mg/l	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	1.0 Maximum Daily			5X Weekly	Grab

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 405-6821	04/24/2024		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From: To:					
3/1/2024	3/31/2024				

Parameter		Quantity (or Loading	Units	Qual	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
BOD, Carbonaceous 05 Day,	Sample Measurement	135	169	11. (1	****	3.3	4.0			3X Weekly test	24-Hr Composite
20C (80082) EFFLUENT GROSS VALUE	Permit 938 1407 Requirement Monthly Average Weekly Average		lbs/day	****	25.0 Monthly Average	37.5 Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite	
BOD, Carbonaceous 05 Day,	Sample Measurement	3186	3895	lbs/day	****	79	84	mg/l	0	3X Weekly test	24-Hr Composite
20C (80082) RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average			3X Weekly test	24-Hr Composite
BOD, Carb-5 Day, 20 Deg C,	Sample Measurement	****	****	****	96	****	****	%	0	Monthly	Calculated
Percent Remvl (80091) Percent Removal	Permit Requirement	****	****	*****	85.0 Monthly Average Minimum	****	****			Monthly	Calculated
Solids, Suspended Percent	Sample Measurement	****	****	****	91	****	****	0/	0	Monthly	Calculated
Removal (81011) Percent Removal	Permit Requirement	****	****	**************************************	85.0 Monthly Average Minimum	****	****	%	0	Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 405-6821	04/24/2024		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408

Monitoring Period

From: To: 3/1/2024 3/31/2024

END OF REPORT

NAME OF PR	INCIPAL	EXEC	UTIVE
OFFICER OR	AUTHOR	IZED	ACENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE	
Electronically Signed via AEPACS	(256) 405-6821	04/24/2024	

Submission Identifier: DMR-AL0058408-20240331-1

Submission Signature Hash: nmb9ktU9S+NDf/ISlv5/IWG0tWSMzFVmjB5YCfE6FXA=

Submitter Name: Max Gaskins

Submitter Email: mgaskins@oxfordwater.com

Submitted Date/Time: 4/24/2024 1:21:28 PM