Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408					
Monitoring Period					
From:	To:				
5/1/2024	5/31/2024				

Digitally signed by: AEPACS Date: 2024.06.25 10:49:59 -05:00 Reason: Copy Of Record Location: State of Alabama

Outfall: 001-1

Parameter		Quantity (or Loading	Units	Qual	lity or Concentr	ration	Units	No. Ex.	Sample Freq	Sample Type
Turbidity (00070)	Sample Measurement	****	****	****	****	1.52	2.31	NTU	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily		U	5X Weekly	Grab
Oxygen, Dissolved (DO) (00300)	Sample Measurement	****	****	****	7.41	****	****	- mg/l - S.U. - mg/l	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	****			3X Weekly test	Grab
pH (00400)	Sample Measurement	****	****	****	7.07	****	7.54		0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily	****	9.0 Maximum Daily			3X Weekly test	Grab
Solids, Total Suspended (00530)	Sample Measurement	255	275	11 /1	****	10.2	11.7			3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average		0	3X Weekly test	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 405-6821	06/25/2024		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
To: 5/31/2024					

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Solids, Total Suspended (00530)	Sample Measurement	3685	5343	lbs/day	****	156	222	- mg/l	0	3X Weekly test	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	ios/day	****	REPORT Monthly Average	REPORT Weekly Average		U	3X Weekly test	24-Hr Composite
Nitrogen, Ammonia Total (As	Sample Measurement	14.1	16.66	11/-1	****	0.60	0.67	mg/l		3X Weekly test	24-Hr Composite
N) (00610) EFFLUENT GROSS VALUE	Permit Requirement	37.5 Monthly Average	56.2 Weekly Average	lbs/day	****	1.0 Monthly Average	1.5 Weekly Average		0	3X Weekly test	24-Hr Composite
Nitrogen, Kjeldahl Total (As N)	Sample Measurement	33	33	lbs/day -	****	1.5	1.5	mg/l	0	Monthly	24-Hr Composite
(00625) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average			Monthly	24-Hr Composite
Nitrite Plus Nitrate Total 1 Det.	Sample Measurement	26	26	11 /1	****	1.2	1.2			Monthly	24-Hr Composite
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system,	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	(256) 405-6821	06/25/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From:	To:				
5/1/2024	5/31/2024				

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Phosphorus, Total (As P) (00665)	Sample Measurement	4	4	lbs/day	****	0.19	0.19	- mg/l		Monthly	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	ios/day	****	REPORT Monthly Average	REPORT Weekly Average		0	Monthly	24-Hr Composite
Silver Total Recoverable (01079)	Sample Measurement	****	****	****	****	*B	*B	ug/I	0	Monthly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily			Monthly	Grab
Color (ADMI Units) (01290)	Sample Measurement	****	****	****	****	****	53	ADMI	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	80 Maximum Daily	ADMI		5X Weekly	Grab
Flow, In Conduit or Thru Treatment Plant (50050) EFFLUENT GROSS VALUE	Sample Measurement	3.00	3.99		****	****	****	****	0	Daily	Continuous
	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****			Daily	Continuous

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 405-6821	06/25/2024

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No: AL0058408					
Monitoring Period					
From:	To:				
5/1/2024	5/31/2024				

Parameter		Quantity (or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Chlorine, Total Residual (50060)	Sample Measurement	****	****	****	****	*9	*9	m c /l	0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily	mg/l	0		Grab
E. Coli (51040)	Sample Measurement	****	****	****	****	22	56	- col/100mL	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	126 Monthly Average	298 Maximum Daily		O O	3X Weekly test 3X Weekly test 5X Weekly 5X Weekly Monthly Monthly 5X Weekly	Grab
Cyanide, Free Available (51173)	Sample Measurement	****	****	*****	****	*B	*B	- ug/l	0	3X Weekly test 5X Weekly 5X Weekly Monthly Monthly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	31.4 Monthly Average	70.5 Maximum Daily		0		Grab
Peracetic Acid (51674)	Sample Measurement	****	****		****	****	0.19		0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	****	****	****	1.0 Maximum Daily	mg/l	0	5X Weekly	Grab

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 405-6821	06/25/2024		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Outfall: 001-1

Permit No:	AL0058408			
Monitoring Period				
From:	To:			
5/1/2024	5/31/2024			

Parameter		Quantity of	or Loading	Units	Qual	ity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	85	85	lbs/day	****	3.4	3.8	mg/l		3X Weekly test	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	300 Monthly Average	450 Weekly Average	ios/day	****	8.0 Monthly Average	12.0 Weekly Average	mg/i	0	3X Weekly test 3X Weekly test	24-Hr Composite
BOD, Carbonaceous 05 Day, 20C (80082)	Sample Measurement	1854	2038	lbs/day	****	78	82	- mg/l - %	0	3X Weekly test Monthly	24-Hr Composite
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average		O O		24-Hr Composite
BOD, Carb-5 Day, 20 Deg C,	Sample Measurement	****	****	****	96	****	****		0		Calculated
Percent Remvl (80091) Percent Removal	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****		0	Monthly	Calculated
Solids, Suspended Percent	Sample Measurement	****	****		91	****	****		0	Monthly	Calculated
Removal (81011) Percent Removal	Permit Requirement	****	****	****	85.0 Monthly Average Minimum	****	****	%	0	Monthly	Calculated

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 405-6821	06/25/2024		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No:	AL0058408				
Monitoring Period					
From:	To:				
5/1/2024	5/31/2024				

Outfall: 001-T

Parameter		Quantity of	or Loading	Units	Qual	ity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type
Toxicity, Ceriodaphnia Chronic	Sample Measurement	****	*9	pass=0;fail=1 -	****	****	****	- ****		See Permit Requirements	24-Hr Composite
(61426) EFFLUENT GROSS VALUE	Permit Requirement	****	0 Single Sample		****	****	****		0	See Permit Requirements	24-Hr Composite
Toxicity, Pimephales Chronic	Sample Measurement	****	*9	pass=0;fail=1	****	****	****	****		See Permit Requirements	24-Hr Composite
(61428) EFFLUENT GROSS VALUE	Permit Requirement	****	0 Single Sample	pass=0,1411=1	****	****	****	- *****			24-Hr Composite

NAME OF PRINCIPAL EXECUTIVE
OFFICER OR AUTHORIZED AGENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE		
Electronically Signed via AEPACS	(256) 405-6821	06/25/2024		

Permittee Name: Water Works & Sewer Board of the City of Oxford

Facility Name: Oxford Tull C. Allen WWTP Location: 2975 Silver Run Road

Oxford, AL 36203

County: Talladega

Permit No: AL0058408

Monitoring Period

From: To: 5/1/2024 5/31/2024

END OF REPORT

NAME OF PR	INCIPAL	EXEC	CUTIVE
OFFICER OR	AUTHOR	IZED	ACENT

Max Gaskins

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Electronically Signed via AEPACS	(256) 405-6821	06/25/2024

Submission Identifier: DMR-AL0058408-20240531-1

 $\textbf{Submission Signature Hash:} \ V/8c175daSWAJKG3gMug4SzbU+DmMneFTwalWJUpbXo=\\$

Submitter Name: Max Gaskins

Submitter Email: mgaskins@oxfordwater.com

Submitted Date/Time: 6/25/2024 10:49:59 AM