Digitally signed by: AEPACS Date: 2023.11.20 10:49:01 -06:00 Reason: Copy Of Record Location: State of Alabama

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408			
Facility Name:	Oxford Tull C. Allen WWTP	Monitorir	ng Period		
Location:	2975 Silver Run Road Oxford, AL 36203	From: 10/1/2023	To: 10/31/2023		
County:	Talladega				

Parameter		Quantity o	or Loading	Units	Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type			
Turbidity (00070)	Sample Measurement	****	****	****	****	2.45	4.7	NTU	0	5X Weekly	Grab		
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	REPORT Monthly Average	REPORT Maximum Daily	NIU	0	5X Weekly	Grab		
Oxygen, Dissolved (DO) (00300)	Sample Measurement	****	****	****	7.69	****	****	— mg/l	mo/l		0	3X Weekly test	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	6.0 Minimum Daily	****	****		0	3X Weekly test	Grab		
рН (00400)	Sample Measurement	****	****	****	6.85	****	7.40	C LI	0	3X Weekly test	Grab		
EFFLUENT GROSS VALUE	Permit Requirement	****	****		6.0 Minimum Daily		3.0.	0	3X Weekly test	Grab			
(00530) EFFLUENT GROSS VALUE	Sample Measurement	148	240		****	8.2	13	- mg/l	0	3X Weekly test	24-Hr Composite		
	Permit Requirement	1125 Monthly Average	1688 Weekly Average	lbs/day	****	30.0 Monthly Average	45.0 Weekly Average			3X Weekly test	24-Hr Composite		

AME OF PRINCIPAL EXECUTIVE FICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 405-6821	11/20/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408			
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period			
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 10/1/2023	To: 10/31/2023		

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type		
Solids, Total Suspended (00530)	Sample Measurement	1874	3338	11	****	110	181	(1	0	3X Weekly test	24-Hr Composite		
RAW SEW/INFLUENT	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	3X Weekly test	24-Hr Composite		
Nitrogen, Ammonia Total (As N) (00610)	Sample Measurement	4.95	8.62	lbs/dev	****	0.28	0.49	— mg/l	mall	mg/l	0	3X Weekly test 2	24-Hr Composite
EFFLUENT GROSS VALUE	Permit Requirement	37.5 Monthly Average	56.2 Weekly Average	lbs/day	****	1.0 Monthly Average	1.5 Weekly Average	mg/1		3X Weekly test	24-Hr Composite		
Nitrogen, Kjeldahl Total (As N)	Sample Measurement	5	5	11 / 1	****	0.29	0.29		0	Monthly	24-Hr Composite		
(00625) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite		
Nitrite Plus Nitrate Total 1 Det.	Sample Measurement	79	79	11	****	4.7	4.7		0	Monthly	24-Hr Composite		
(As N) (00630) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite		

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 405-6821	11/20/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408				
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period				
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 10/1/2023	To: 10/31/2023			

Parameter		Quantity of	or Loading	Units	Qua	lity or Concentr	ation	Units	No. Ex.	Sample Freq	Sample Type				
Phosphorus, Total (As P)	Sample Measurement	32	32	11-0 (4	****	1.9	1.9	(1	0	Monthly	24-Hr Composite				
(00665) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average	lbs/day	****	REPORT Monthly Average	REPORT Weekly Average	mg/l	0	Monthly	24-Hr Composite				
Silver Total Recoverable (01079)	Sample Measurement	****	****	****	****	*В	*В	- ug/l	ug/l	uc/l	uc/1	uc/1	0	Monthly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	REPORT Monthly Average	REPORT Maximum Daily		0	Monthly	Grab				
Color (ADMI Units) (01290)	Sample Measurement	****	****	**	****	****	77	ADMI	0	5X Weekly	Grab				
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	80 Maximum Daily	ADMI	0	5X Weekly	Grab				
Flow, In Conduit or Thru	Sample Measurement	2.17	3.25	MGD	****	****	****	****	0	Daily	Continuous				
Treatment Plant (50050) EFFLUENT GROSS VALUE	Permit Requirement	REPORT Monthly Average	REPORT Maximum Daily	MGD	****	****	****		0	Daily	Continuous				

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.	Electronically Signed via AEPACS	(256) 405-6821	11/20/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408			
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period			
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 10/1/2023	To: 10/31/2023		

Parameter		Quantity o	or Loading	Units	Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type		
Chlorine, Total Residual	Sample Measurement	****	****	****	****	*9	*9		0	3X Weekly test	Grab	
(50060) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	0.066 Monthly Average	0.115 Maximum Daily	mg/l	0	3X Weekly test	Grab	
E. Coli (51040)	Sample Measurement	****	****	****	****	26	72	col/100mL	oo1/100mJ	0	5X Weekly	Grab
EFFLUENT GROSS VALUE	Permit Requirement	****	****	*****	****	126 Monthly Average	298 Maximum Daily		0	5X Weekly	Grab	
Cyanide, Free Available	Sample Measurement	****	****	****	****	*В	*В	1	0	Monthly	Grab	
(51173) EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	31.4 Monthly Average	70.5 Maximum Daily	ug/l	0	Monthly	Grab	
Peracetic Acid (51674)	Sample Measurement	****	****	****	****	****	0.25		0	5X Weekly	Grab	
EFFLUENT GROSS VALUE	Permit Requirement	****	****		****	****	1.0 Maximum Daily	mg/l	0	5X Weekly	Grab	

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	I certify under penalty of law that this document and all attachments were prepared under my direction or	SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins	or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.		(256) 405-6821	11/20/2023

Permittee Name: Water Works & Sewer Board of the City of Oxford		Permit No: AL0058408		
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period		
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 10/1/2023	To: 10/31/2023	

Parameter		Quantity o	Quantity or Loading Units		Units Quality or Concentration		Units Quality or Concentration		Units Quality or Concentration		Units	No. Ex.	Sample Freq	Sample Type
BOD, Carbonaceous 05 Day, 20C (80082) EFFLUENT GROSS VALUE	Sample Measurement	66	64	- lbs/day	****	3.6	3.8	mg/l		3X Weekly test	24-Hr Composite			
	Permit Requirement	300 Monthly Average	450 Weekly Average		****	8.0 Monthly Average	12.0 Weekly Average		0	3X Weekly test	24-Hr Composite			
BOD, Carbonaceous 05 Day, 20C (80082) RAW SEW/INFLUENT	Sample Measurement	1300	1423	- lbs/day	****	78	82	- mg/l	0	3X Weekly test	24-Hr Composite			
	Permit Requirement	REPORT Monthly Average	REPORT Weekly Average		****	REPORT Monthly Average	REPORT Weekly Average			3X Weekly test	24-Hr Composite			
BOD, Carb-5 Day, 20 Deg C, Percent Remvl (80091) Percent Removal	Sample Measurement	****	****	- ****	95	****	****	- %	0	Monthly	Calculated			
	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****			Monthly	Calculated			
Solids, Suspended Percent Removal (81011) Percent Removal	Sample Measurement	****	****	****	92	****	****	- %		Monthly	Calculated			
	Permit Requirement	****	****		85.0 Monthly Average Minimum	****	****		0	Monthly	Calculated			

	CIPAL EXECUTIVE UTHORIZED AGENT		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max	Gaskins			(256) 405-6821	11/20/2023

Permittee Name:	Water Works & Sewer Board of the City of Oxford	Permit No: AL0058408		
Facility Name:	Oxford Tull C. Allen WWTP	Monitoring Period		
Location: County:	2975 Silver Run Road Oxford, AL 36203 Talladega	From: 10/1/2023	To: 10/31/2023	

END OF REPORT

NAME OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT		SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT	TELEPHONE NO.	DATE
Max Gaskins			(256) 405-6821	11/20/2023

Submission Identifier:DMR-AL0058408-20231031-1Submission Signature Hash:ISY4ZQsMo5n+Pxcg5zP4u4Ks2Z6DgAM/m4ZLqtIWX0U=Submitter Name:Max GaskinsSubmitter Email:mgaskins@oxfordwater.com

Submitted Date/Time: 11/20/2023 10:49:00 AM